

PowerGard universal receptacles and back boxes

Cl. I, Groups B, C, D
Cl. II, Groups F, G
Cl. III
NEMA 3, 3R, 3RX

Explosionproof
Dust-ignitionproof
Raintight
Wet Locations

9P

Ordering information:

Receptacles and mounting boxes

Type	Style	Configuration	Hub size	Cat. # 20A, 125 VAC	Cat. # 20A, 250 VAC	Cat. # 15A, 125 VAC
	Dead end	2-wire, 3-pole	1/2"	CFS150-2023-M15	CFS150-20232-M15	CFS150-1523-M15
			3/4"	CFS175-2023-M15	CFS175-20232-M15	CFS175-1523-M15
			1"	CFS110-2023-M15	CFS110-20232-M15	CFS110-1523-M15
	Through feed	2-wire, 3-pole	1/2"	CFSC150-2023-M15	CFSC150-20232-M15	CFSC150-1523-M15
			3/4"	CFSC175-2023-M15	CFSC175-20232-M15	CFSC175-1523-M15
			1"	CFSC110-2023-M15	CFSC110-20232-M15	CFSC110-1523-M15
	Dead end	2-wire, 3-pole	1/2"	CFS250-2023-M15	CFS250-20232-M15	CFS250-1523-M15
			3/4"	CFS275-2023-M15	CFS275-20232-M15	CFS275-1523-M15
			1"	CFS210-2023-M15	CFS210-20232-M15	CFS210-1523-M15
	Through feed	2-wire, 3-pole	1/2"	CFSC250-2023-M15	CFSC250-20232-M15	CFSC250-1523-M15
			3/4"	CFSC275-2023-M15	CFSC275-20232-M15	CFSC275-1523-M15
			1"	CFSC210-2023-M15	CFSC210-20232-M15	CFSC210-1523-M15

Replacement receptacles

Type	Configuration	Cat. # 20A, 125 VAC [Ⓔ]	Cat. # 20A, 250 VAC [Ⓔ]	Cat. # 15A, 125 VAC [Ⓔ]
	2-wire, 3-pole	 CFSR-2023-M15 [Ⓓ]	 CFSR-20232-M15	 CFSR-1523-M15 [Ⓓ]

Ark-Gard ENP plug

Type	Configuration	Cat. # 20A, 125 VAC	Cat. # 20A, 250 VAC	Cat. # 15A, 125 VAC
	2-wire, 3-pole	 ENP5201	 ENP6202	 ENP5151

Back boxes

	Type	Style	Hub size	Cat. #		Type	Style	Hub size	Cat. #
	Single-gang	Dead end	1/2"	CFD150		Two-gang	Dead end	1/2"	CFD250
			3/4"	CFD175				3/4"	CFD275
			1"	CFD110				1"	CFD210
		Through feed	1/2"	CFDC150			Through feed	1/2"	CFDC250
			3/4"	CFDC175				3/4"	CFDC275
			1"	CFDC110				1"	CFDC210

Replacement parts

Type	Cat. #	Type	Cat. #	Type	Cat. #
	PGSCA		PGTCA		PG SCREW PACK
					PG SCREW PACK SLOT

[Ⓑ] Single-gang assembly listed for Class I, Division 1, Groups B, C, D for -25°C ambient and Class I, Division 1, Groups C, D for -50°C ambient.

[Ⓒ] Two-gang assembly listed for Class I, Division 1, Groups C, D and Class I, Division 2, Groups B, C, D. Manufacturer self-certification of Class I, Division 1, Group B available.

[Ⓓ] In order to be certified for Class I, Division 1, Group B applications, receptacles must be used on a single-gang back box (catalog number CFD1XX or CFDC1XX).

[Ⓔ] Both 15A, 125 VAC and 20A, 125 VAC PowerGard receptacles can accept either a 15A, 125 VAC or 20A, 125 VAC ENP plug.